



Air Handler #1 - Uma-01 - Total Load Summary

Air Handler Description: Uma-01 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0,48 HP
 Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
 Sensible Heat Ratio: 0,93 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 4pm in August.
 Outdoor Conditions: Clg: 89° DB, 84° WB, 175,74 grains
 Indoor Conditions: Clg: 72° DB, 50% RH

Summer: Ventilation controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	0 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		0 Btuh

Heating Supply Air: $0 / (.974 \times 1,08 \times 0) =$	0 CFM
Winter Vent Outside Air (0,0% of supply) =	0 CFM

Room space sensible gain:	108.107 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	1.190 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		109.298 Btuh

Cooling Supply Air: $109.298 / (.974 \times 1,1 \times 20) =$	5.101 CFM
Summer Vent Outside Air (18,2% of supply) =	930 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	16.931 Btuh	930 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		16.931 Btuh
Total sensible gain on air handling system:		126.229 Btuh

Room space latent gain:	7.700 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	70.675 Btuh	
Total latent gain on air handling system:		78.375 Btuh
Total system sensible and latent gain:		204.604 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	5.101 CFM
Total Air Handler Vent. Air (18,22% of Supply):	930 CFM
Total Conditioned Air Space:	2.846 Sq.ft
Supply Air Per Unit Area:	1,7924 CFM/Sq.ft
Area Per Cooling Capacity:	166,9 Sq.ft/Ton
Cooling Capacity Per Area:	0,0060 Tons/Sq.ft
Heating Capacity Per Area:	0,00 Btuh/Sq.ft
Total Heating Required With Outside Air:	0 Btuh
Total Cooling Required With Outside Air:	17,05 Tons



Air Handler #1 - Uma-01 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
1	Z-01 P1 Cubiculo	169	0	4.131	440	2AC/Hr	2AC/Hr
	Aislado 2	2	0	300	300	0	55
	5pm August	1.656	0,00	1,78	300	0	55
2	Z-02 P1 Esclusa	42	0	1.076	220	2AC/Hr	2AC/Hr
	Aislado	1	0	70	70	0	14
	5pm August	414	0,00	1,66	70	0	13
3	Z-03 P1 Cubiculo 8 Al	130	0	3.737	440	2AC/Hr	2AC/Hr
	14	2	0	170	0	0	42
	5pm August	1.274	0,00	1,31	0	0	31
The above Room occurs 7 times throughout this air system.							
4	Z-04 P1 Transfer De	151	0	4.269	440	2AC/Hr	2AC/Hr
	Camillas	2	0	194	150	0	49
	2pm August	1.483	0,00	1,28	150	0	35
9	Z-09 P1 Esclusa	108	0	3.669	440	2AC/Hr	2AC/Hr
	2pm August	2	0	167	0	0	35
		1.060	0,00	1,54	0	0	30
10	Z-10 P1 Filtro Visitantes	135	0	5.892	880	2AC/Hr	2AC/Hr
	2pm August	4	0	268	0	0	44
		1.319	0,00	1,99	0	0	49
11	Z-11 P1 Deposito	40	0	1.382	220	2AC/Hr	2AC/Hr
	Material Esteril	1	0	63	0	0	13
	2pm August	389	0,00	1,58	0	0	11
12	Z-12 P1 Ropa Limpia	53	0	1.632	220	2AC/Hr	2AC/Hr
	2pm August	1	0	74	0	0	17
		522	0,00	1,39	0	0	14
13	Z-13 P1 Tintos	58	0	3.216	220	2AC/Hr	2AC/Hr
	2pm August	1	0	146	0	0	19
		566	0,00	2,53	0	0	27
14	Z-14 P1 Trabajo Limpio	59	0	1.248	220	2AC/Hr	2AC/Hr
	5pm August	1	0	57	0	0	19
		581	0,00	0,96	0	0	10
22	Z-22 P1 Corredor	471	0	33.974	440	2AC/Hr	2AC/Hr
	4pm August	2	0	1.545	270	0	154
		4.615	0,00	3,28	270	0	282
23	Z-23 P1 Corredor	650	0	22.617	880	2AC/Hr	2AC/Hr
	3pm August	4	0	1.028	0	0	212
		6.372	0,00	1,58	0	0	187
	Room Peak Totals:	2.846	0	109.268	7.700		
	Total Rooms: 18	35	0	5.101	790	0	930
	Unique Rooms: 12	27.892	0,00	1,79	790	0	930



Air Handler #2 - Uma-02 - Total Load Summary

Air Handler Description: Uma-02 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0,51 HP
 Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
 Sensible Heat Ratio: 0,93 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 3pm in August.
 Outdoor Conditions: Clg: 90° DB, 84° WB, 174,75 grains
 Indoor Conditions: Clg: 72° DB, 50% RH

Summer: Ventilation controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	0 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		0 Btuh

Heating Supply Air: $0 / (.974 \times 1,08 \times 0) =$	0 CFM
Winter Vent Outside Air (0,0% of supply) =	0 CFM

Room space sensible gain:	110.038 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	1.270 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	5.299 Btuh	
Total sensible gain on supply side of coil:		116.607 Btuh

Cooling Supply Air: $116.607 / (.974 \times 1,1 \times 20) =$	5.443 CFM
Summer Vent Outside Air (30,0% of supply) =	1.632 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	31.477 Btuh	1.632 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		31.477 Btuh
Total sensible gain on air handling system:		148.084 Btuh

Room space latent gain:	8.140 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	122.289 Btuh	
Total latent gain on air handling system:		130.429 Btuh
Total system sensible and latent gain:		278.513 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	5.443 CFM
Total Air Handler Vent. Air (29,99% of Supply):	1.632 CFM
Total Conditioned Air Space:	4.997 Sq.ft
Supply Air Per Unit Area:	1,0891 CFM/Sq.ft
Area Per Cooling Capacity:	215,3 Sq.ft/Ton
Cooling Capacity Per Area:	0,0046 Tons/Sq.ft
Heating Capacity Per Area:	0,00 Btuh/Sq.ft
Total Heating Required With Outside Air:	0 Btuh
Total Cooling Required With Outside Air:	23,21 Tons



Air Handler #2 - Uma-02 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
15	Z-15 P1 Corredor 8am August	259 2 2.540	0 0 0,00	10.926 372 1,44	440 150 150	2AC/Hr 0 0	2AC/Hr 85 112
16	Z-16 P1 Cubiculo 1 AI 7 5pm August	130 2 1.274	0 0 0,00	3.737 127 0,98	440 0 0	2AC/Hr 0 0	2AC/Hr 42 38
The above Room occurs 7 times throughout this air system.							
17	Z-17 P1 Cubiculo Aislado 1 5pm August	169 2 1.656	0 0 0,00	4.131 300 1,78	440 300 300	2AC/Hr 0 0	2AC/Hr 55 90
18	Z-18 P1 Esclusa Aislado 5pm August	42 1 414	0 0 0,00	1.076 70 1,66	220 70 70	2AC/Hr 0 0	2AC/Hr 14 21
19	Z-19 P1 Estacion Enfermeria 5pm August	2.820 13 27.632	0 0 0,00	41.766 2.763 0,98	2.860 680 680	2AC/Hr 0 0	2AC/Hr 921 829
20	Z-20 P1 Deposito Insumos 5pm August	85 1 829	0 0 0,00	1.504 83 0,98	220 0 0	2AC/Hr 0 0	2AC/Hr 28 25
21	Z-21 P1 Circulacion Visitantes 6pm August	713 4 6.986	0 0 0,00	28.312 964 1,35	880 0 0	2AC/Hr 0 0	2AC/Hr 233 289
Room Peak Totals:		4.997	0	113.875	8.140		
Total Rooms: 13		37	0	5.444	1.200	0	1.632
Unique Rooms: 7		48.974	0,00	1,09	1.200	0	1.633



Air Handler #10 - Umsp-01 - Total Load Summary

Air Handler Description: Umsp-01 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0,02 HP
 Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
 Sensible Heat Ratio: 0,86 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 1pm in August.
 Outdoor Conditions: Clg: 87° DB, 84° WB, 178,39 grains
 Indoor Conditions: Clg: 72° DB, 50% RH

Because of the diversity in room, plenum and ventilation loads, the room sensible peak time in August at 2pm is different from the total system peak time, hence the air system CFM was computed using a room sensible load of 5.613.

Summer: Ventilation controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	0 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		0 Btuh

Heating Supply Air: $0 / (,974 \times 1,08 \times 0) =$	0 CFM
Winter Vent Outside Air (0,0% of supply) =	0 CFM

Room space sensible gain:	5.567 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	62 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		5.629 Btuh

Cooling Supply Air: $5.675 / (,974 \times 1,1 \times 20) =$	265 CFM
Summer Vent Outside Air (17,2% of supply) =	45 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	780 Btuh	45 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		780 Btuh
Total sensible gain on air handling system:		6.408 Btuh

Room space latent gain:	880 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	3.558 Btuh	
Total latent gain on air handling system:		4.438 Btuh
Total system sensible and latent gain:		10.846 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	265 CFM
Total Air Handler Vent. Air (17,17% of Supply):	45 CFM
Total Conditioned Air Space:	139 Sq.ft
Supply Air Per Unit Area:	1,9022 CFM/Sq.ft
Area Per Cooling Capacity:	154,0 Sq.ft/Ton
Cooling Capacity Per Area:	0,0065 Tons/Sq.ft
Heating Capacity Per Area:	0,00 Btuh/Sq.ft
Total Heating Required With Outside Air:	0 Btuh
Total Cooling Required With Outside Air:	0,90 Tons



Air Handler #10 - Umsp-01 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
5	Z-05 P1 Estar De Personal 2pm August	139 4 1.365	0 0 0,00	5.613 265 1,90	880 0 0	2AC/Hr 0 0	2AC/Hr 45 45
	Room Peak Totals:	139	0	5.613	880		
	Total Rooms: 1	4	0	265	0	0	45
	Unique Rooms: 1	1.365	0,00	1,90	0	0	45



Air Handler #11 - Umsp-02 - Total Load Summary

Air Handler Description: Umsp-02 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0,02 HP
 Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
 Sensible Heat Ratio: 0,84 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 1pm in August.
 Outdoor Conditions: Clg: 87° DB, 84° WB, 178,39 grains
 Indoor Conditions: Clg: 72° DB, 50% RH

Because of the diversity in room, plenum and ventilation loads, the room sensible peak time in August at 2pm is different from the total system peak time, hence the air system CFM was computed using a room sensible load of 4.458.

Summer: Ventilation controls outside air, ----- Winter: Exhaust controls outside air.

Room Space sensible loss:	0 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		0 Btuh

Heating Supply Air: $0 / (,974 \times 1,08 \times 0) =$	0 CFM
Winter Vent Outside Air (0,0% of supply) =	0 CFM

Room space sensible gain:	4.417 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	49 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		4.466 Btuh

Cooling Supply Air: $4.507 / (,974 \times 1,1 \times 20) =$	210 CFM
Summer Vent Outside Air (24,3% of supply) =	51 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	875 Btuh	51 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		875 Btuh
Total sensible gain on air handling system:		5.341 Btuh

Room space latent gain:	880 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	3.993 Btuh	
Total latent gain on air handling system:		4.873 Btuh
Total system sensible and latent gain:		10.213 Btuh

Check Figures

Total Air Handler Supply Air (based on a 20° TD):	210 CFM
Total Air Handler Vent. Air (24,26% of Supply):	51 CFM
Total Conditioned Air Space:	156 Sq.ft
Supply Air Per Unit Area:	1,3463 CFM/Sq.ft
Area Per Cooling Capacity:	183,6 Sq.ft/Ton
Cooling Capacity Per Area:	0,0054 Tons/Sq.ft
Heating Capacity Per Area:	0,00 Btuh/Sq.ft
Total Heating Required With Outside Air:	0 Btuh
Total Cooling Required With Outside Air:	0,85 Tons



Air Handler #11 - Umsp-02 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
6	Z-06 P1 Coordinacion 2pm August	156 4 1.531	0 0 0,00	4.458 210 1,35	880 0 0	2AC/Hr 0 0	2AC/Hr 51 51
	Room Peak Totals:	156	0	4.458	880		
	Total Rooms: 1	4	0	210	0	0	51
	Unique Rooms: 1	1.531	0,00	1,35	0	0	51



Air Handler #20 - Upa-01 - Total Load Summary

Air Handler Description: Upa-01 Constant Volume - Proportion
 Supply Air Fan: Draw-Thru with program estimated horsepower of 0,19 HP
 Fan Input: 0% motor and fan efficiency with 0 in. water across the fan
 Sensible Heat Ratio: 0,82 --- This system occurs 1 time(s) in the building. ---

Air System Peak Time: 1pm in August.
 Outdoor Conditions: Clg: 87° DB, 84° WB, 178,39 grains
 Indoor Conditions: Clg: 72° DB, 55% RH

Summer: Ventilation controls outside air, ---- Winter: Exhaust controls outside air.

Room Space sensible loss:	0 Btuh	
Infiltration sensible loss:	0 Btuh	0 CFM
Outside Air sensible loss:	0 Btuh	0 CFM
Supply Duct sensible loss:	0 Btuh	
Return Duct sensible loss:	0 Btuh	
Return Plenum sensible loss:	0 Btuh	
Total System sensible loss:		0 Btuh

Heating Supply Air: $0 / (.974 \times 1,08 \times 0) =$	0 CFM
Winter Vent Outside Air (0,0% of supply) =	0 CFM

Room space sensible gain:	41.141 Btuh	
Infiltration sensible gain:	0 Btuh	
Draw-thru fan sensible gain:	477 Btuh	
Supply duct sensible gain:	0 Btuh	
Reserve sensible gain:	0 Btuh	
Total sensible gain on supply side of coil:		41.618 Btuh

Cooling Supply Air: $41.618 / (.974 \times 1,1 \times 19) =$	2.045 CFM
Summer Vent Outside Air (10,3% of supply) =	210 CFM

Return duct sensible gain:	0 Btuh	
Return plenum sensible gain:	0 Btuh	
Outside air sensible gain:	3.599 Btuh	210 CFM
Blow-thru fan sensible gain:	0 Btuh	
Total sensible gain on return side of coil:		3.599 Btuh
Total sensible gain on air handling system:		45.217 Btuh

Room space latent gain:	8.820 Btuh	
Infiltration latent gain:	0 Btuh	
Outside air latent gain:	15.581 Btuh	
Total latent gain on air handling system:		24.401 Btuh
Total system sensible and latent gain:		69.619 Btuh


Check Figures

Total Air Handler Supply Air (based on a 19° TD):	2.045 CFM
Total Air Handler Vent. Air (10,27% of Supply):	210 CFM
Total Conditioned Air Space:	928 Sq.ft
Supply Air Per Unit Area:	2,2025 CFM/Sq.ft
Area Per Cooling Capacity:	160,0 Sq.ft/Ton
Cooling Capacity Per Area:	0,0062 Tons/Sq.ft
Heating Capacity Per Area:	0,00 Btuh/Sq.ft
Total Heating Required With Outside Air:	0 Btuh
Total Cooling Required With Outside Air:	5,80 Tons




Air Handler #20 - Upa-01 - Summary Loads

Rm No	Description Room Peak Time	Area People Volume	Htg.Loss Htg.CFM CFM/Sqft	Sen.Gain Clg.CFM CFM/Sqft	Lat.Gain S.Exh W.Exh	Htg.O.A. Req.CFM Act.CFM	Clg.O.A. Req.CFM Act.CFM
7	Z-07 P1 Sala De	864	0	38.423	8.400	5/P	5/P
	Espera	40	0	1.909	190	0	200
	1pm August	8.471	0,00	2,21	190	0	196
8	Z-08 P1 Informacion	64	0	2.726	420	5/P	5/P
	2pm August	2	0	135	0	0	10
		627	0,00	2,12	0	0	14
	Room Peak Totals:	928	0	41.149	8.820		
	Total Rooms: 2	42	0	2.045	190	0	210
	Unique Rooms: 2	9.098	0,00	2,20	190	0	210

	HOSPITAL SARARE	
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 23 de 28


7.1.4 Anexo CALCULO EXTRACCIONES MECANICAS

	MEMORIA DE CÁLCULOS: EXTRACCIONES PUNTUALES			AG-MC 001	VERSIÓN 0
	PROYECTO	P19-46 HOSPITAL SARAVE	UBICACIÓN	SARAVENA - ARAUCA	DISEÑADOR

ANOTACIONES		
FECHA	30/05/2019	
REVISION	1	D Castro
ANOTACIONES	Version Inicial	30/05/2019

TABLA DE DATOS																	
PISO	ZONA	ITEM	CANTIDAD	SISTEMA VE-XX	AREA EXTRACCION	AREA** mts 2	ALTURA** mts	UNIDADES*** Sanit y Orinales	CAMBIOS / HORA ****	CFM/UNID	CFM -CAMBIOS	CFM-UNIDAD	EXTRACCION DIRECTA	CFM	CFM AJUSTADOS	CFM POR CANTIDAD	OBSERVACIONES
		ZE-01 P1	1	0	CUBICULO AISLADO 2	15.61	3	0	10	70	279	0		279	300	300	0
		ZE-02 P1	1	0	ESCLUSA AISLADO	3.99	3	0	10	70	71	0		71	70	70	0
		ZE-03 P1	1	0	BAÑO AISLADO	3.69	3	1	10	70	66	70		70	70	70	0
		ZE-04 P1	1	0	ASEO	4.19	3	0	10	70	75	0		75	80	80	0
		ZE-05 P1	1	0	RESIDUOS	5.86	3	0	20	70	209	0		209	200	200	0
		ZE-06 P1	1	0	ROPA SUJIA	5.86	3	0	10	70	105	0		105	100	100	0
		ZE-07 P1	1	0	LAVADO DE PATOS	5.86	3	0	10	70	105	0		105	100	100	0
		ZE-08 P1	1	0	TRABAJO SUJIO	5.86	3	0	10	70	105	0		105	100	100	0
		ZE-09 P1	1	0	CUBICULO AISLADO 1	15.61	3	0	10	70	279	0		279	300	300	0
		ZE-10 P1	1	0	BAÑO AISLADO	3.7	3	1	10	70	66	70		70	70	70	0
		ZE-11 P1	1	0	ESCLUSA AISLADO	4	3	0	10	70	71	0		71	70	70	0
		ZE-12 P1	1	0	UNIDAD SANITARIA	5.39	3	1	10	70	96	70		96	100	100	0
		ZE-13 P1	1	0	BAÑO PUBLICO MUJERES	3.05	3	1	10	70	54	70		70	70	70	0
		ZE-14 P1	1	0	ASEO	1.75	3	0	10	70	31	0		31	50	50	0
		ZE-15 P1	1	0	BAÑO PUBLICO HOMBRES	3.05	3	1	10	70	54	70		70	70	70	0
		ZE-16 P1	1	0	BAÑO MUJERES	4.15	3	1	10	70	74	70		74	70	70	0
		ZE-17 P1	1	0	BAÑO HOMBRES	4.15	3	1	10	70	74	70		74	70	70	0
		ZE-18 P1	1	0	BAÑO	1.8	3	1	10	70	32	70		70	70	70	0
			0	0		0	3	0	10	70	0	0		-	0	0	0

* Basado en ANSI/ASHRAE ct 62.1-2004
 ** Solo para calculos x Cambios Hora
 **** Basado en ASHRAE Hospital and clinics

	HOSPITAL SARARE	 INGENIERIA DEL AIRE S.A.S.
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 24 de 28

7.1.5 Anexo CALCULO DE DUCTOS

Ductulator®

VariTrane™ Duct Designer


Duct ID	Airflow cfm	Length ft	Width in.	Height in.	Diameter in.	Velocity fpm	Friction Rate in H2O/100 ft	Circular Equivalent in.	Pressure Drop in. wg	Section Area sq ft	Perimeter in.	Aspect Ratio	Reynolds Number	Altshul Friction Factor	Cole- Brook Friction Factor	Density lb/cu ft
0001	375	10.0	14.0	4.9		792	0.150	8.8	0.0119	0.47	37.7	2.88	62,273	0.02	0.02	0.077
0002	750	10.0	14.0	7.8		990	0.150	11.3	0.0130	0.76	43.6	1.80	100,687	0.02	0.02	0.077
0003	1,125	10.0	14.6	10.0		1,111	0.150	13.2	0.0133	1.01	49.2	1.46	131,446	0.02	0.02	0.077
0004	1,500	10.0	18.4	10.0		1,174	0.150	14.7	0.0129	1.28	56.8	1.84	154,921	0.02	0.02	0.077
0005	2,050	10.0	18.0	12.8		1,286	0.150	16.5	0.0133	1.59	61.5	1.41	191,066	0.02	0.02	0.077
0006	270	10.0	10.0	5.1		758	0.150	7.7	0.0128	0.36	30.3	1.95	52,709	0.02	0.02	0.077
0007	470	10.0	10.0	7.6		893	0.150	9.5	0.0134	0.53	35.2	1.32	76,343	0.02	0.02	0.077
0008	670	10.0	12.4	8.0		971	0.150	10.9	0.0132	0.69	40.8	1.55	94,680	0.02	0.02	0.077
0009	870	10.0	15.3	8.0		1,023	0.150	12.0	0.0129	0.85	46.6	1.91	109,996	0.02	0.02	0.077
0010	1,070	10.0	16.0	8.9		1,083	0.150	12.9	0.0130	0.99	49.8	1.80	125,794	0.02	0.02	0.077
0011	1,200	10.0	15.3	10.0		1,126	0.150	13.5	0.0132	1.07	50.7	1.53	136,522	0.02	0.02	0.077
0012	2,300	10.0	21.1	12.0		1,306	0.150	17.3	0.0130	1.76	66.3	1.76	202,728	0.02	0.02	0.077
0013	2,550	10.0	22.0	12.5		1,339	0.150	18.0	0.0129	1.90	68.9	1.77	216,117	0.02	0.02	0.077
0014	4,270	10.0	25.1	16.0		1,529	0.150	21.8	0.0131	2.79	82.3	1.57	299,934	0.02	0.02	0.077
0015	4,470	10.0	26.1	16.0		1,543	0.150	22.2	0.0131	2.90	84.1	1.63	307,955	0.02	0.02	0.077
0016	440	10.0	10.0	7.2		877	0.150	9.3	0.0133	0.50	34.5	1.38	73,117	0.02	0.02	0.077
0017	260	10.0	10.0	5.0		749	0.150	7.6	0.0128	0.35	30.0	2.00	51,364	0.02	0.02	0.077
0018	610	10.0	11.5	8.0		951	0.150	10.5	0.0133	0.64	39.1	1.44	89,592	0.02	0.02	0.077
0019	5,080	10.0	28.9	16.0		1,581	0.150	23.3	0.0129	3.21	89.8	1.81	331,144	0.02	0.02	0.077
0020	700	10.0	10.0	10.1		993	0.150	11.0	0.0135	0.70	40.3	1.01	98,495	0.02	0.02	0.077
0021	900	10.0	12.3	10.0		1,056	0.150	12.1	0.0134	0.85	44.5	1.23	114,995	0.02	0.02	0.077
0022	600	10.0	10.0	9.1		954	0.150	10.4	0.0135	0.63	38.1	1.10	89,345	0.02	0.02	0.077
0023	800	10.0	11.2	10.0		1,027	0.150	11.6	0.0135	0.78	42.4	1.12	107,008	0.02	0.02	0.077
0024	1,000	10.0	13.3	10.0		1,082	0.150	12.6	0.0134	0.92	46.6	1.33	122,545	0.02	0.02	0.077
0025	1,200	10.0	15.3	10.0		1,126	0.150	13.5	0.0132	1.07	50.7	1.53	136,522	0.02	0.02	0.077
0026	1,400	10.0	17.4	10.0		1,158	0.150	14.3	0.0130	1.21	54.8	1.74	148,982	0.02	0.02	0.077
0027	2,500	10.0	22.6	12.0		1,327	0.150	17.8	0.0128	1.88	69.2	1.88	212,492	0.02	0.02	0.077
0028	450	10.0	14.0	5.5		842	0.150	9.4	0.0122	0.53	39.0	2.55	70,810	0.02	0.02	0.077
0029	2,950	10.0	25.9	12.0		1,366	0.150	19.0	0.0126	2.16	75.8	2.16	232,829	0.02	0.02	0.077
0030	300	10.0			8.9	700	0.094	8.9	0.0094	0.43	27.8	1.00	55,723	0.02	0.02	0.077
0031	380	10.0	6.5	10.0		840	0.150	8.8	0.0132	0.45	33.0	1.54	66,360	0.02	0.02	0.077
0032	680	10.0	9.9	10.0		986	0.150	10.9	0.0135	0.69	39.9	1.01	96,704	0.02	0.02	0.077
0033	980	10.0	13.1	10.0		1,077	0.150	12.5	0.0134	0.91	46.2	1.31	121,066	0.02	0.02	0.077
0034	600	10.0	9.1	10.0		954	0.150	10.4	0.0135	0.63	38.1	1.10	89,345	0.02	0.02	0.077
0035	1,200	10.0	15.3	10.0		1,126	0.150	13.5	0.0132	1.07	50.7	1.53	136,522	0.02	0.02	0.077
0036	2,480	10.0	22.5	12.0		1,325	0.150	17.8	0.0129	1.87	68.9	1.87	211,543	0.02	0.02	0.077
0037	5,430	10.0	30.5	16.0		1,600	0.150	23.9	0.0128	3.39	93.1	1.91	343,721	0.02	0.02	0.077
0038	570	10.0	10.0	8.7		941	0.150	10.2	0.0134	0.61	37.4	1.15	86,460	0.02	0.02	0.077
0039	770	10.0	10.0	10.9		1,017	0.150	11.4	0.0135	0.76	41.8	1.09	104,506	0.02	0.02	0.077
0040	970	10.0	13.0	10.0		1,075	0.150	12.5	0.0134	0.90	46.0	1.30	120,330	0.02	0.02	0.077
0041	1,380	10.0	24.0	7.6		1,088	0.150	14.2	0.0116	1.27	63.2	3.15	139,153	0.02	0.02	0.077
0042	3,080	10.0	24.0	13.2		1,400	0.150	19.3	0.0129	2.20	74.4	1.82	242,545	0.02	0.02	0.077
0043	400	10.0	10.0	6.8		853	0.150	9.0	0.0132	0.47	33.5	1.48	68,660	0.02	0.02	0.077
0044	250	10.0	8.7	8.7		500	0.046	9.6	0.0046	0.53	34.9	1.00	42,991	0.02	0.02	0.077
0045	1,010	10.0	13.4	10.0		1,084	0.150	12.7	0.0133	0.93	46.8	1.34	123,268	0.02	0.02	0.077
0046	4,090	10.0	28.3	14.0		1,487	0.150	21.5	0.0127	2.75	84.6	2.02	286,917	0.02	0.02	0.077
0047	1,990	10.0	26.0	9.1		1,205	0.150	16.4	0.0119	1.65	70.3	2.84	177,020	0.02	0.02	0.077

Ductulator®

VariTrane™ Duct Designer

Duct ID	Airflow cfm	Length ft	Width in.	Height in.	Diameter in.	Velocity fpm	Friction Rate in H2O/100 ft	Circular Equivalent in.	Pressure Drop in. wg	Section Area sq ft	Perimeter in.	Aspect Ratio	Reynolds Number	Altshul Friction Factor	Cole- Brook Friction Factor	Density lb/cu ft
0048	2,120	10.0	20.0	11.9		1,285	0.150	16.8	0.0130	1.65	63.8	1.68	193,285	0.02	0.02	0.077
0049	4,460	10.0	30.4	14.0		1,509	0.150	22.2	0.0125	2.95	88.8	2.17	300,861	0.02	0.02	0.077
0050	660	10.0	9.7	10.0		978	0.150	10.8	0.0135	0.67	39.4	1.03	94,907	0.02	0.02	0.077
0051	760	10.0	10.8	10.0		1,014	0.150	11.4	0.0135	0.75	41.6	1.08	103,653	0.02	0.02	0.077
0052	1,420	10.0	17.6	10.0		1,162	0.150	14.4	0.0130	1.22	55.2	1.76	150,195	0.02	0.02	0.077
0053	2,080	10.0	24.1	10.0		1,241	0.150	16.6	0.0123	1.68	68.3	2.41	185,331	0.02	0.02	0.077
0054	1,780	10.0	26.0	8.5		1,162	0.150	15.7	0.0117	1.53	69.0	3.06	163,636	0.02	0.02	0.077
0055	580	10.0	10.0	8.8		946	0.150	10.3	0.0134	0.61	37.7	1.13	87,430	0.02	0.02	0.077
0056	680	10.0	12.6	8.0		974	0.150	10.9	0.0132	0.70	41.1	1.57	95,508	0.02	0.02	0.077
0057	1,080	10.0	14.1	10.0		1,101	0.150	13.0	0.0133	0.98	48.3	1.41	128,311	0.02	0.02	0.077
0058	440	10.0	12.0	6.2		858	0.150	9.3	0.0128	0.51	36.3	1.95	71,602	0.02	0.02	0.077

Number of Duct Sections Specified: 58

	HOSPITAL SARARE	 INGENIERIA DEL AIRE S.A.S.
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 25 de 28

7.1.6 Anexo TUBERIAS DE REFIRGERACION

Refrigerant Line Sizing

Dataset Name: UMAE-01

Refrigerant : R410A
Pipe type : L - Copper Tubing

SUCTION LINE				DISCHARGE LINE				LIQUID LINE				
Size in.	Velocity fpm	PD psig	Minimum ¹ Tons	Size in.	Velocity fpm	PD psig	Minimum ¹ Tons	Size in.	Velocity fpm	PD psig	Ref Charge lb of refrig	Subcooling °F
3/8	26,497	4,418.1		3/8	9,266	1,593.7		3/8	949	96.0	3	-
1/2	13,869	847.0	0.3	1/2	4,850	291.4	0.4	1/2	497	23.9	6	8.1
5/8	8,632	216.8	0.5	5/8	3,019	81.1	0.8	5/8	309	11.3	10	10.4
3/4	5,780	91.5	0.9	3/4	2,021	32.1	1.3	3/4	207	7.8	14	11.0
7/8	4,161	38.7	1.3	7/8	1,455	14.2	2.0	7/8	149	7.0	20	11.2
1 1/8	2,440	10.4	2.6	1 1/8	853	3.8	3.9	1 1/8	87	6.2	34	11.3
1 3/8	1,602	3.7	4.3	1 3/8	560	1.3	6.6	1 3/8	57	6.0	52	11.4
1 5/8	1,132	1.6	6.7	1 5/8	396	0.5	10.2	1 5/8	41	6.0	74	11.4
2 1/8	651	0.2	13.3	2 1/8	228	0.1	20.5	2 1/8	23	5.9	128	11.4
2 5/8	422	0.0	22.9									

Suction Pressure: 118.47 psig
Saturated Suction: 40.0 °F
Suction Temperature: 48.0 °F
Specific Enthalpy: 123.7 Btu / lbm
Specific Volume: 0.467 ft³ / lbm
Volumetric Flow Rate: 13.98 cfm
Superheat Temp: 8.0 °F

Condenser Pressure: 446.46 psig
Condensing Temperature: 125.0 °F
Specific Volume: 0.163 ft³ / lbm
Volumetric Flow Rate: 4.9 cfm
Mass Flow Rate: 1,796.9 lbm / hr
Delta H: 66.8 Btu / lbm
Comp. Superheat Temp: 70.0 °F

Liquid Temperature: 110.0 °F
Specific Enthalpy: 57.0 Btu / lbm
Density: 59.79 lbm / ft³
Volumetric Flow Rate: 3.75 gpm
Specific Gravity: 0.958
Liquid Line Static Head: 0.0 psig
Evap Tonnage: 10.0 tons
Subcooling Temperature: 15.0 °F

Dataset Name: UMAE-02

Refrigerant : R410A
Pipe type : L - Copper Tubing

SUCTION LINE				DISCHARGE LINE				LIQUID LINE				
Size in.	Velocity fpm	PD psig	Minimum ¹ Tons	Size in.	Velocity fpm	PD psig	Minimum ¹ Tons	Size in.	Velocity fpm	PD psig	Ref Charge lb of refrig	Subcooling °F
3/8	26,497	4,418.1		3/8	9,266	1,593.7		3/8	949	96.0	3	-
1/2	13,869	847.0	0.3	1/2	4,850	291.4	0.4	1/2	497	23.9	6	8.1
5/8	8,632	216.8	0.5	5/8	3,019	81.1	0.8	5/8	309	11.3	10	10.4
3/4	5,780	91.5	0.9	3/4	2,021	32.1	1.3	3/4	207	7.8	14	11.0
7/8	4,161	38.7	1.3	7/8	1,455	14.2	2.0	7/8	149	7.0	20	11.2
1 1/8	2,440	10.4	2.6	1 1/8	853	3.8	3.9	1 1/8	87	6.2	34	11.3
1 3/8	1,602	3.7	4.3	1 3/8	560	1.3	6.6	1 3/8	57	6.0	52	11.4
1 5/8	1,132	1.6	6.7	1 5/8	396	0.5	10.2	1 5/8	41	6.0	74	11.4
2 1/8	651	0.2	13.3	2 1/8	228	0.1	20.5	2 1/8	23	5.9	128	11.4
2 5/8	422	0.0	22.9									

Suction Pressure: 118.47 psig
Saturated Suction: 40.0 °F
Suction Temperature: 48.0 °F
Specific Enthalpy: 123.7 Btu / lbm
Specific Volume: 0.467 ft³ / lbm
Volumetric Flow Rate: 13.98 cfm
Superheat Temp: 8.0 °F

Condenser Pressure: 446.46 psig
Condensing Temperature: 125.0 °F
Specific Volume: 0.163 ft³ / lbm
Volumetric Flow Rate: 4.9 cfm
Mass Flow Rate: 1,796.9 lbm / hr
Delta H: 66.8 Btu / lbm
Comp. Superheat Temp: 70.0 °F

Liquid Temperature: 110.0 °F
Specific Enthalpy: 57.0 Btu / lbm
Density: 59.79 lbm / ft³
Volumetric Flow Rate: 3.75 gpm
Specific Gravity: 0.958
Liquid Line Static Head: 0.0 psig
Evap Tonnage: 10.0 tons
Subcooling Temperature: 15.0 °F


Note: Optimum size is highlighted for all three lines

Note: In a heat pump unit the Vapor line is the suction line in cooling and becomes the discharge line in heating.

1 - Minimum refrigerant capacity for oil entrapment up risers

2 - Unrecognized Model Number

- Horiz. and Vert. Drops - Vertical Risers - Horizontal, Drops, and Vertical Risers

	HOSPITAL SARARE	 INGENIERIA DEL AIRE S.A.S.
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 26 de 28

7.1.7 Anexo CALENDARIO ELECTRICO



MEMORIA DE CÁLCULOS: CALENDARIO ELECTRICO

AG-MC-002

VERSIÓN 0

PROYECTO

P19-46 HOSPITAL SARAVE

UBICACIÓN

SARAVENA - ARAUCA

DISEÑADOR

Ing Diego Gonzalo Castro

ANOTACIONES

FECHA	26/06/2019	
REVISION	1	D Castro
ANOTACIONES	Version Inicial	26/06/2019


TABLA DE DATOS

ITEM	UBICACIÓN	EQUIPO	TABLERO	DATOS (V/F/Hz)			DATOS PLACA		POTENCIA (Kwatt)	CONSUMO (A)	BRAKER (A)
				V	F	Hz					
UNIDAD MANEJADORA DE AIRE	CUBIERTA	UMAE-01	1	220	3	60	7,5	HP	5,60	24,0	3x30A
UNIDAD MANEJADORA DE AIRE	CUBIERTA	UMAE-02	1	220	3	60	7,5	HP	5,60	24,0	3x30A
UNIDAD PAQUETE	CUBIERTA	UPA-01	1	220	3	60	26	MCA	9,91	26,0	3x30A
UNIDAD CONDENSADORA	CUBIERTA	UC-01	1	220	3	60	98	MCA	37,34	98,0	3x100A
UNIDAD CONDENSADORA	CUBIERTA	UC-02	1	220	3	60	98	MCA	37,34	98,0	3x100A
UNIDAD DE EXTRACCION TIPO HONGO	CUBIERTA	VE-01	1	220	3	60	0,5	HP	0,37	2,4	3x3A
UNIDAD DE EXTRACCION TIPO HONGO	CUBIERTA	VE-02	1	220	3	60	0,25	HP	0,19	2,3	2x3A
UNIDAD DE EXTRACCION TIPO HONGO	CUBIERTA	VE-03	1	220	3	60	0,25	HP	0,19	2,3	2x3A
UNIDAD MINISPLIT	CUBIERTA	UCMPS/UMSP/01	1	220	2	60	1,2	KW	1,20	3,9	2x15A
UNIDAD MINISPLIT	CUBIERTA	UCMPS/UMSP/02	1	220	2	60	1,2	KW	1,20	3,9	2x15A

MCA = MAXIMUN CURRENT AMPACITY
 FLA = FULL LOAD AMPACITY
 KW = KILO WATT
 HP = CABALLOS DE FUERZA

RESUMEN EJECUTIVO

CARGA TOTAL Kw	98,9
NUMERO TABLEROS	1,0

	HOSPITAL SARARE	
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 27 de 28

7.1.8 Anexo SISTEMA DE CONTROL

MODIFICACIONES	
05/07/2019	VERSION PARA PROGRAMACION

NOTAS

DISEÑO:
Ing Diego Gonzalo Castro G.
CN230-44378

REVISO: _____

APROBO: _____

ESCALA:
SIN

VERSION: **R0** FECHA: **JULIO 2019**


ARCHIVO:
IA-17-30 TOPOLOGIA DE RED

DIBUJO:
D.C





PLANO:
01

DE:
01

AC-01



UBICADO EN EL TABLERO



UBICADOS EN TAPA

TE-01

UC-01

UC-02

TDA

BR

TDA

BR

(4) 2x22 AWG


(4) 2x22 AWG

(4) 2x22 AWG

(4) 2x22 AWG

2x22 AWG

2x22 AWG

	HOSPITAL SARARE	
Revisión 05/07/19	DISEÑO Y ESTUDIOS TÉCNICOS PARA EL SISTEMA DE HVAC	Pág. 28 de 28

7.2.1 Anexo SELECCIÓN DE EQUIPOS



HOSPITAL SARAVENA

Cliente:

SOLER Y PALAU COLOMBIA, S.A. - Autopista Medellín Km 2.7,
Parque Industrial Los Nogales - Bodega 10, Cota Cundinamarca
(Colombia) / PBX: +57 01 8000 9157270 Móvil: +57 313 2400879 -
3132928853 Tel: +57 743 8021 Ext: 36113 / e-mail:
comercial@solerpalau.co

Soler&Palau  **Ventilation Group**



CRVL-T

CRVL-T-16-0,5HP/4-1025RPM-(208-230~3)



Los extractores centrífugos CR son una amplia gama de alta eficiencia para montaje en techo.

CRVL-T Extractor centrífugo de montaje en techo, baja Presión, marca S&P, con caudal 1.080 cfm y presión 1,00 Inwg, para aplicaciones de extracción de aire limpio descarga vertical, con transmisión poleas-bandas diseñadas y calculadas acorde a las necesidades requeridas.

Detalles constructivos:

- Fabricado en aluminio rechazado, brinda una apariencia estética, peso ligero y otorga una resistencia contra agentes corrosivos del medio ambiente.
- Los rodetes de álabes rectos atrasados balanceados dinámicamente, están fabricados con aleaciones especiales de aluminio.
- Su diseño aerodinámico, les permite guiar el aire dentro de la estructura del ventilador, sin turbulencia.

Rangos de trabajo:

- Caudal desde 1013 m³ /hr (596 CFM) hasta 5966m³/hr (35139 CFM).
- Con presión máxima de hasta 47.64 mmca (1.87 inwg).

Aplicaciones: desde uso comercial a industrial, donde se requiere extraer aire limpio.

Proyecto: HOSPITAL SARAVERA (rev. 1 (2)) - Referencia producto: VE-01

Punto requerido

Caudal	1.080 cfm
Presión Estática	1,00 Inwg
Temperatura	20 °C
Altitud	223 m
Densidad	1,18 Kg / m ³
Frecuencia	60 Hz
Tensión	208-230~3

Punto de trabajo

Caudal	1.080 cfm
Presión estática	1,00 Inwg @ 1,18 kg/m ³
Presión dinámica	0,019 Inwg @ 1,18 kg/m ³
Presión total	1,02 Inwg @ 1,18 kg/m ³
Presión estática estándar	1,02 Inwg @ 1,2 kg/m ³
Presión dinámica estándar	0,020 Inwg @ 1,2 kg/m ³
Presión total estándar	1,04 Inwg @ 1,2 kg/m ³
Eficiencia	56
Pot Elect absorbida	0,471 hp
Rend Total	55,9 %
Potencia útil	0,311 Hp @ 1,18 kg/m ³
Potencia útil estándar	0,318 Hp @ 1,2 kg/m ³
Factor de Servicio Req	10
Rend Estático	54,8 %
Velocidad descarga	2,9 m/s
Velocidad aspiración	3,5 m/s
Velocidad ventilador	1025 rpm
Potencia específica	0,79 W/l/s


Construcción

Diámetro impulsión	16 mm
Tamaño ventilador	16
Peso	42,18 kg


Características del motor

Número de Polos	4
Potencia motor	0,5 Hp
Tensión	3-208-230/460V-60Hz
Intensidad máxima absorbida	1,9 A / 1,0 A
Índice de protección	IP21
Clase motor	B

Curva



Curva (1,204 Kg / m³)



Características acústicas

	63	125	250	500	1k	2k	4k	8k	Total
Descarga (LwA)	61	73	75	74	73	70	74	65	81
Descarga LpA @ 1,5m	46	58	60	59	58	55	59	50	67



Dimensiones



CRVL-T

CRVL-T-12-0,25HP/4-1300RPM-(208-230~3)



Los extractores centrífugos CR son una amplia gama de alta eficiencia para montaje en techo.

CRVL-T Extractor centrífugo de montaje en techo, baja Presión, marca S&P, con caudal 435 cfm y presión 0,978 inwg, para aplicaciones de extracción de aire limpio descarga vertical, con transmisión poleas-bandas diseñadas y calculadas acorde a las necesidades requeridas.

Detalles constructivos:

- Fabricado en aluminio rechazado, brinda una apariencia estética, peso ligero y otorga una resistencia contra agentes corrosivos del medio ambiente.
- Los rodetes de álabes rectos atrasados balanceados dinámicamente, están fabricados con aleaciones especiales de aluminio.
- Su diseño aerodinámico, les permite guiar el aire dentro de la estructura del ventilador, sin turbulencia.

Rangos de trabajo:

- Caudal desde 1013 m³ /hr (596 CFM) hasta 59666m³/hr (35139 CFM).
- Con presión máxima de hasta 47.64 mmca (1.87 inwg).

Aplicaciones: desde uso comercial a industrial, donde se requiere extraer aire limpio.

Proyecto: HOSPITAL SARAVENA (rev. 1 (2)) - Referencia producto: VE-02 Y 03

Punto requerido

Caudal	440 cfm
Presión Estática	1,00 Inwg
Temperatura	20 °C
Altitud	223 m
Densidad	1,18 Kg / m ³
Frecuencia	60 Hz
Tensión	208-230~3

Punto de trabajo

Caudal	435 cfm
Presión estática	0,978 Inwg @ 1,18 kg/m ³
Presión dinámica	0,011 Inwg @ 1,18 kg/m ³
Presión total	0,989 Inwg @ 1,18 kg/m ³
Presión estática estándar	1,00 Inwg @ 1,2 kg/m ³
Presión dinámica estándar	0,011 Inwg @ 1,2 kg/m ³
Presión total estándar	1,01 Inwg @ 1,2 kg/m ³
Eficiencia	38
Pot Elect absorbida	0,306 hp
Potencia útil	0,177 Hp @ 1,18 kg/m ³
Potencia útil estándar	0,182 Hp @ 1,2 kg/m ³
Factor de Servicio Req	10
Velocidad descarga	2,1 m/s
Velocidad aspiración	2,4 m/s
Velocidad ventilador	1300 rpm
Potencia específica	0,95 W/l/s


Construcción

Diámetro impulsión	12 mm
Tamaño ventilador	12
Peso	35,82 kg


Características del motor

Número de Polos	4
Potencia motor	0,25 Hp
Tensión	3-208-230/460V-60Hz
Intensidad máxima absorbida	1,1 A / 0,6 A
Índice de protección	IP21
Clase motor	B

Curva



Curva (1,204 Kg / m³)



Características acústicas

	63	125	250	500	1k	2k	4k	8k	Total
Descarga (LwA)	48	61	63	64	63	60	64	53	71
Descarga LpA @ 1,5m	33	46	48	49	48	45	49	38	56



Dimensiones